
## Lightning Surge Protectors for Electronics Equipment M-RESTER

# LIGHTNING SURGE PROTECTOR FOR STANDARD SIGNAL LINE

(ultra-slim)

#### **Functions & Features**

- High discharge current capacity 20 kA (8 / 20 $\mu$ s), 1 kA (10 / 350  $\mu$ s)
- Ultra-thin 7-mm-wide module can be mounted in high density
- Excellent protection employing multi-stage SPD circuits
- DIN rail mounting and grounding
- Shield terminal provided
- CE marking



MODEL: MD7ST-[1][2][3][4]

#### ORDERING INFORMATION

Code number: MD7ST-[1][2][3][4]

Specify a code from below for each [1] through [4].

(e.g. MD7ST-24FF00)

For the safety approval code 2, specify the product's destination country using Ordering Information Sheet (No. ESU-8057).

## [1] NOMINAL VOLTAGE

**24**: 24 V DC **60**: 60 V DC

## [2] SHIELD TERMINAL (line / earth)

FF: Floating / Floating
FG: Floating / Grounding
GF: Grounding / Floating
GG: Grounding / Grounding

## [3] LOOP DISCONNECT FUSE

0: Without

1: With (CENELEC/ATEX approval Not selectable)

#### [4] SAFETY APPROVAL

0: None

2: CENELEC intrinsic safety (ATEX)

#### RELATED PRODUCTS

• Loop disconnect fuse (model: MD7F)

#### **GENERAL SPECIFICATIONS**

Construction: Slim-sized front terminal structure

Degree of protection: IP20

Connection: Euro terminal block (torque 0.3 N·m)

Applicable wire size: 0.2 - 2.5 mm<sup>2</sup>

Grounding: DIN Rail

**Housing material**: Flame-resistant resin (black) **Loop disconnect fuse**: Current rating 250 mA

(Separates the protected device from the power source  $% \left( \mathbf{s}\right) =\left( \mathbf{s}^{\prime }\right)$ 

when the former fails in the shortcircuit mode.)

#### **INSTALLATION**

Operating temperature: -25 to +85°C (-13 to +185°F) (See Safety Parameters for use in a hazardous location.)
Operating humidity: 30 to 90 %RH (non-condensing)

Mounting: DIN Rail (TH35-7.5, 1-mm-thick)

FAX: (02)2596-2331 Website: www.xintop.com

Oxide film on the surface of an aluminium rail may lower the electric conductivity between this module and the

ground. Use a steel or copper rail.

Weight: 70 g (2.5 oz)

Website: www.xintop.com

FAX: (02)2596-2331

## **PERFORMANCE**

MODEL NO.	NOMINAL VOLTAGE	MD7ST-24				MD7ST-60				
	SHLD TERMINAL	FF	FG	GF	GG	FF	FG	GF	GG	
Max. continuous operating voltage (Uc)	Line to Line	30V				70V				
	Line to Earth		±160V		30V	±160V			70V	
	Line to SHLD	±160V		30V		±160V		70V		
	SHLD to Earth	±160V	short	±160V	short	±160V	short	±160V	short	
Voltage protection level (Up) @4kV (1.2 / 50 µs)	Line to Line	60V			115V					
	Line to Earth	±800V		±60V	±800V			±115V		
	Line to SHLD	±1200V	±800V	±60V		±1200V ±800V ±115V		I		
	SHLD to Earth	±800V	short	±800V	short	±800V	short	±800V	short	
Leakage current @Uc	Line to Line	≤5µA				≤5µA				
	Other sections	≤5µA				≤5µA				
Response time	Line to Line	≤4 nsec.				≤4 nsec.				
	Other sections	≤20 nsec.				≤20 nsec.				
Max. discharge cur	20kA (8 / 20 μs), 1.0kA (10 / 350 μs)									
Nominal current (I <sub>N</sub> )		250mA								
Internal series resistance	Without fuse	4.7Ω ±10% per line				10Ω ±10% per line				
	With fuse	$7.5\Omega \pm 10\%$ per line				$12.5\Omega \pm 10\%$ per line				

## **STANDARDS & APPROVALS**

#### CE conformity:

ATEX Directive (94/9/EC) Ex ia EN 60079-11: 2007

Category 1G EN 60079-26: 2007 EMC Directive (2004/108/EC) EMI EN 61000-6-4: 2007 EMS EN 61000-6-2: 2005

Safety approval:

CENELEC: Intrinsic safety (ATEX) 

© II 1G, Ex ia IIC; T4 and T5

EN 60079-0: 2006 EN 60079-11: 2007 EN 60079-26: 2007

Surge protection: IEC 61643-21: 2000

(Categories C1, C2, D1)

## **SAFETY PARAMETERS**


#### **■ CENELEC / ATEX IS DATA**

	MD7ST-	24	MD7ST-60			
Ui (Vmax)	32V		60V			
li (Imax)	any		any			
Ci	10 nF		5 nF			
Li	0 μΗ		0 μΗ			
	Temp. Class	Range		Parameter		
		-25 to +40°C		1.3W		
Pi	T4	-25 to +60 $^{\circ}\mathrm{C}$		1.2W		
		-25 to +80°C		1.0W		
	T5	-25 to +40°C		1.0W		

### **DESCRIPTIONS**


#### ■ SELECTING SHIELD TERMINAL TYPE

- The surge protector has a dedicated shield terminal effective for easy shield wiring and surge protection.
- Review the shield method (grounding, non-grounding, connecting to SG, etc.) required by the protected device or system.
- There is no electrical effect to the shield by installing the surge protector, but an appropriate shield terminal type must be selected to suit user applications.
- Refer to the flow chart below to choose.



#### ■ SELECTING LOOP DISCONNECT FUSE

- Specify 'Loop disconnect fuse' type when multiple transmitters are connected to single power bus.
- Loop disconnect fuse is used to separate a transmitter loop from the power bus when it fails in the shortcircuit mode.




幸託有限公司 XIN TOP CORPORATION

TEL: (02)2598-1199 E-mail: info@xintop.com


FAX: (02)2596-2331 Website: www.xintop.com

## **CONNECTION EXAMPLES**



- \*1.Oxide film on the surface of an aluminium rail may lower the electric conductivity between this module and the ground. Use a steel or copper rail.
- \*2.Be sure to ground the DIN rail. Recommended grounding resistance ≤100Ω
- \*3. Cross-wire between the DIN rail and the metal housing of the protected device to equalize the earth potential. Ground only the surge protector when the protected device has no ground terminal.
- \*4.Shield wiring method is an example. Proceed according to the system requirements.


## **EXTERNAL DIMENSIONS & TERMINAL ASSIGNMENTS unit: mm (inch)**



幸託有限公司 FAX: (02)2596-2331 Website: www.xintop.com

XIN TOP CORPORATION

## **SCHEMATIC CIRCUITRY**





幸託有限公司 XIN TOP CORPORATION

TEL: (02)2598-1199 E-mail: info@xintop.com

FAX: (02)2596-2331 Website: www.xintop.com

E-mail: info@xintop.com

Website: www.xintop.com

Specifications are subject to change without notice.