Lightning Surge Protectors for Electronics Equipment M-RESTER

## LIGHTNING SURGE PROTECTOR FOR **STRAIN GAUGE USE**


#### **Functions & Features**

• Designed to protect strain gauge transmitters from

lightning surge damage that enters on the wiring between the strain gauge and the transmitter

• Absorbs surges only without affecting instrumentation signal

• No interruption of signal by unplugging the protector element



## MODEL: MDP-LC[1]

#### ORDERING INFORMATION

 Code number: MDP-LC[1] Specify a code from below for [1]. (e.g. MDP-LC/A33)

## [1] OPTIONS

**DIN rail mounting adapter** blank: Without /A33: With adapter (model A-33)

### **GENERAL SPECIFICATIONS**

Construction: Plug-in Connection: M4 screw terminals (torque 0.8 N·m) Screw terminal: Nickel-plated steel Housing material: Flame-resistant resin (black)

#### INSTALLATION

Operating temperature: -5 to +55°C (23 to 131°F) Operating humidity: 30 to 90 %RH (non-condensing) Mounting: Surface or DIN rail Weight: 100 g (0.22 lbs), standard; 125 g (0.28 lbs), with DIN rail mounting adapter

幸託有限公司

XIN TOP CORPORATION

#### PERFORMANCE

Max. continuous operating voltage (Uc): Output side: ±0.3 V min



Excitation side: 15 V min Line to earth: ±15 V min Voltage protection level (Up): • @ Imax Output side: ±15 V max Excitation side: 30 V max Line to earth: ±30 V max **Response time**:  $\leq$  5 nsec. Leakage current: Output side:  $\leq$  0.2 µA @ ±0.3 V DC Excitation side:  $\leq 2 \ \mu A @ 15 \ V DC$ Line to earth:  $\leq$  2 µA @ ±15 V DC Max. discharge current (Imax) Output side: 100 A (8/20 µs), 25 A (10/1000 µs) Excitation side: 50 A (8/20 µs), 25 A (10/1000 µs) Line to earth: 50 A (8/20 µs), 25 A (10/1000 µs) Capacitance @ 1 MHz: Output side:  $\leq 100 \text{ pF}$ Excitation side:  $\leq 4 \text{ nF}$ 


## **STANDARDS & APPROVALS**

Line to earth:  $\leq 2 \text{ nF}$ 


Surge protection: IEC 61643-21 (Categorie C3)

TEL: (02)2598-1199 E-mail: info@xintop.com FAX: (02)2596-2331 Website: www.xintop.com

#### **CONNECTION EXAMPLES**



### GROUNDING



A crossover wire between M-RESTER ground and the ground or metallic housing of the equipment is required for protection. If the protected equipment has no ground terminal, ground the M-RESTER only.

When the M-RESTER is mounted with DIN Rail Mounting Adapter, connect the grounding wire to the mounting screw of the M-RESTER.







FAX : (02)2596-2331

TEL: (02)2598-1199 E-mail: info@xintop.com Website : www.xintop.com

#### **EXTERNAL DIMENSIONS & TERMINAL ASSIGNMENTS unit: mm (inch)**

STANDARD






# **MOUNTING REQUIREMENTS unit: mm (inch)**

幸託有限公司

**XIN TOP CORPORATION** 






TEL: (02)2598-1199 E-mail: info@xintop.com FAX : (02)2596-2331

Website : www.xintop.com

## **SCHEMATIC CIRCUITRY & CONNECTION DIAGRAM**



 $\square$ 

Specifications are subject to change without notice.





TEL: (02)2598-1199 E-mail: info@xintop.com FAX : (02)2596-2331

Website : www.xintop.com