# Lightning Surge Protectors for **Electronics Equipment M-RESTER**

## LIGHTNING SURGE PROTECTOR FOR POWER SUPPLY USE


(100 / 110 / 120 V AC, single phase)

#### **Functions & Features**

• Designed for installation where AC power enters the control panel for relatively large power consuming equipment such as large instrumentation panels, computer systems or telemetering systems in central control rooms or operation centers

• Composed of air-core reactors, large capacity discharge elements and electromagnetic contactors

• Thermal fuse in parallel with the discharge element opens and cuts off the operating circuit for the electromagnetic contactor in case of discharge elements failure, thus protecting the equipment connected to the arrester



# MODEL: MH-1201

#### **ORDERING INFORMATION**

Code number: MH-1201

#### **GENERAL SPECIFICATIONS**

Connection

Primary side: M12 screw terminals Secondary side: M10 screw terminals Screw terminal: Nickel-plated brass Housing material: Steel plate t = 1.6 (black)

#### INSTALLATION

Operating temperature: -5 to +55°C (23 to 131°F) Operating humidity: 30 to 90 %RH (non-condensing) Mounting: Surface Weight: 35 kg (77.2 lbs)

XIN TOP CORPORATION



#### PERFORMANCE


Discharge voltage (peak voltage) Line to line: 190 V min. Line to ground: 410 V min. Maximum surge voltage Line to line: 350 V max. Line to ground: 700 V max. (The maximum voltage that could pass through M-RESTER. Protected equipment must be able to withstand this voltage for very short time period.) **Response time**:  $\leq 0.1 \ \mu sec$ . Leakage current Line to line:  $\leq$  1 A (at rated voltage, including relay coil current) Line to ground:  $\leq$  1mA at 150 V DC Discharge current capacity: 10000 A (8/ 20 µsec.) Maximum load current: 200 A Voltage drop:  $\leq 2 \vee (50/60 \text{ Hz})$ 

Rated line voltage: 100 V / 110 V / 120 V AC


幸託有限公司

TEL: (02)2598-1199 E-mail: info@xintop.com FAX: (02)2596-2331 Website: www.xintop.com

#### **CONNECTION EXAMPLES**




#### GROUNDING



A crossover wire between M-RESTER ground and ground or metallic housing of equipment is required for protection. If the protected equipment has no ground terminal, ground the M-RESTER only.

### **DIMENSIONS unit: mm (inch)**






幸託有限公司

XIN TOP CORPORATION

FAX : (02)2596-2331

TEL: (02)2598-1199 E-mail: info@xintop.com Website : www.xintop.com

## **SCHEMATIC CIRCUITRY & CONNECTION DIAGRAM**



 $\wedge$ Specifications are subject to change without notice.





FAX : (02)2596-2331

TEL: (02)2598-1199 E-mail: info@xintop.com Website : www.xintop.com