Final Control Elements

MINI-TOP ELECTRONIC ACTUATOR


(linear type; CC-Link)

Functions & Features

- Small-size control valve actuator
- Direct connection to CC-Link capable PLC and other devices on the same network
- Easy wired
- Uploading device information via CC-Link for maintenance purpose
- •1/1000 high resolution

Typical Applications

- For small size proportional control valve in paper manufacturing or co-generation system
- · Air conditioning for buildings and factories
- · Chemical injection at water treatment plant



MODEL: MSP6C-[1][2][3]-0R

ORDERING INFORMATION

• Code number: MSP6C-[1][2][3]-0R Specify a code from below for each [1] through [3]. (e.g. MSP6C-331-0R)

[1] STROKE

3: 10 to 20 mm (.39" to .79") **4**: 20 to 40 mm (.79" to 1.57")

[2] OPERATION TIME, THRUST

3: 5 sec. / 10 mm, 600 N **4**: 8 sec. / 10 mm, 1200 N **6**: 15 sec. / 10 mm, 2500 N

[3] OUTPUT STEM TYPE

6: M6 female thread, 0.75 pitch

8: M8 female thread, 1.0 pitch

1: M10 female thread, 1.25 pitch

D: M6 female thread, 1.0 pitch

E: M8 female thread, 1.25 pitch

F: M10 female thread, 1.5 pitch

CE MARKING

0: Without

POWER INPUT

DC Power

R: 24 V DC

(Operational voltage range 24 V ±10 %, ripple 10 %p-p max.)

GENERAL SPECIFICATIONS

Degree of protection: IP55

Operation at a communication error: Extend, retract or stop **Power circuit connection**: 4-core microconnector, male **Power cable**: Cable with connector (e.g. OMRON XS2F or

XS2WD42)

Transmission cable: Conforms to CC-Link (e.g. Woodhead CC-Link Micro-Change) **Housing material**: Cast aluminum

Drive: Stepping motor

Position detection: Potentiometer

Deadband: 0.1 - 1.9 % adjustable (factory set to 1.5 %)

Restarting timer: 0 - 10 sec. adjustable

(factory set to 1.5 sec.)

Isolation: Housing or communication to power

Zero adjustment: 0 - 25 % Span adjustment: 50 - 100 %

Protective functions: Overload protection

Status indicator LED: Red light blinks in 2 sec. intervals in normal operations; blinks in 0.5 sec. intervals when a foreign object is detected mechanically caught inside.

Manual operating handle: Not available

CC-Link COMMUNICATION

Protocol: CC-Link V1.10

Device type: Remote device station **Station No. setting**: Rotary switch; 1 – 64

Required node: 1

Baud rate setting: Rotary switch L RUN indicator: Red LED L ERR. indicator: Red LED

OUTPUT SPECIFICATIONS

■ Operation Time & Torque (at rated power voltage)

[Model: Operation Time: Thrust]

MSP6C-x3: 5 sec. /10 mm 600 N (135 lbf) MSP6C-x4: 8 sec. /10 mm 1200 N (270 lbf) MSP6C-x6: 15 sec. /10 mm 2500 N (562 lbf)



TEL: (02)2598-1199 E-mail: info@xintop.com

Website: www.xintop.com

FAX: (02)2596-2331

INSTALLATION

Power consumption
• DC: Approx. 0.5 A

Operating temperature: -5 to +55°C (23 to 131°F)
Operating humidity: 30 to 85 %RH (non-condensing)

Vibration: 0.5 G (4.9 m/s²) max. **Mounting position**: All directions

Do not mount the actuator with its output stem or cable connector on the upside if the actuator is to be exposed to

dripping water. **Weight**: 3.0 kg (6.6 lb)

PERFORMANCE

Resolution: 1/1000 or 0.015 mm, whichever is greater, with

0.1 % deadband setting

Insulation resistance: \geq 100 M Ω with 100 V DC Dielectric strength: 100 V AC @ 1 minute (housing or communication to power)

COMMUNICATIONS

■MASTER to SLAVE

| DATA TYPE | ADDRESS | FUNCTION | DETAIL |
|-----------|---------|------------------------------------|---|
| | RY0 | Forced Closed Position Input *1 | 0 : Disable 1 : Position = 0% |
| | RY1 | Forced Open Position Input *1 | 0 : Disable 1 : Position = 100% |
| | RY2 | | |
| | RY3 | | |
| | RY4 | | |
| | RY5 | | |
| | RY6 | | |
| Bit | RY7 | | |
| | RY8 | Enable Target Position Input | 0 : Disable 1 : Enable |
| | RY9 | | |
| | RYA | Reset Motor Deadlock Alarm | Motor deadlock alarm is cancelled when '1' is set. |
| | RYB | Clear Motor Starting Counter | Motor starting counter is reset to 0 when '1' is set. |
| | RYC | Clear Motor Reversing Counter | Motor reversing counter is reset to 0 when '1' is set. |
| | RYD | Clear Accumulated Running Distance | Accumulated running distance is reset to 0 when '1' is set. |
| | RYE | | |
| | RYF | | |
| Word | RWw0 | Target Position Input | Signed, 0.01% increments (e.g. 100 = 1.00%) |
| | | | Valid only when Enable Target Position Input is enabled. |
| | RWw1 | | |
| | RWw2 | | |
| | RWw3 | | |

^{*1.} Valid regardless of the RY8 (Enable Target Position Input) status. Stopped when '1' is set both at RY0 and RY1.

■SLAVE to MASTER

| SLAVE to MASTER | | | | | | | |
|-----------------|--|--|--|--|--|--|--|
| ADDRESS | FUNCTION | DETAIL | | | | | |
| RX0 | | | | | | | |
| RX1 | | | | | | | |
| RX2 | | | | | | | |
| RX3 | | | | | | | |
| RX4 | | | | | | | |
| RX5 | | | | | | | |
| RX6 | | | | | | | |
| RX7 | | | | | | | |
| RX8 | Motor Deadlock Alarm | 0 : Normal 1 : Overload or other deadlock alarm | | | | | |
| RX9 | Target Position Input Error | 0 : Normal 1 : Out of range from -0.5 to +100.5% | | | | | |
| RXA | System Error | 0: Normal 1: Memory or other system error | | | | | |
| RXB | Control Status | 0 : Remote (CC-Link) 1 : Manual | | | | | |
| RXC | | | | | | | |
| RXD | | | | | | | |
| RXE | | | | | | | |
| RXF | | | | | | | |
| RWr0 | Position Output | Signed, 0.01% increments (e.g. 100 = 1.00%) | | | | | |
| RWr1 | Motor Starting Counter *2 | 1 count per every 100 starting actions | | | | | |
| RWr2 | Ü | 1 count per every 100 reversing actions | | | | | |
| RWr3 | - | 1 count per running 100% distance every time | | | | | |
| | ADDRESS RX0 RX1 RX2 RX3 RX4 RX5 RX6 RX7 RX8 RX9 RXA RXB RXC RXD RXE RXF RWr0 RWr1 RWr2 | ADDRESS FUNCTION RX0 RX1 RX2 RX3 RX4 RX5 RX6 RX7 RX8 Motor Deadlock Alarm RX9 Target Position Input Error RXA System Error RXB Control Status RXC RXD RXE RXF RWr0 Position Output RWr1 Motor Starting Counter *2 RWr2 Motor Reversing Counter *2 | | | | | |


^{*2.} When the count reaches 65535, the value is held until it is reset.



幸託有限公司 TEL: (02)2598-1199 E-mail: info@xintop.com XIN TOP CORPORATION FAX: (02)2596-2331 Website: www.xintop.com


DIMENSIONS unit: mm (inch)

| OUTPUT STEM HOLE SIZE M | | | | | | | |
|-------------------------|------|-------|-------|--|--|--|--|
| CODE | DIA. | PITCH | DEPTH | | | | |
| 6 | M 6 | 0.75 | | | | | |
| 8 | M 8 | 1.0 | | | | | |
| 1 | M10 | 1.25 | 15 | | | | |
| D | M 6 | 1.0 | | | | | |
| Е | M 8 | 1.25 | | | | | |
| F | M10 | 1.5 | | | | | |



FAX: (02)2596-2331 Website: www.xintop.com

SCHEMATIC CIRCUITRY



 \triangle

Specifications are subject to change without notice.

幸託有限公司

XIN TOP CORPORATION FAX: (02)2596-2331

TEL: (02)2598-1199 E-mail: info@xintop.com

Website: www.xintop.com